

IN TERMS OF REGULATION 21.17.2 OF THE MINERALS ACT
(INCORPORATED IN THE MINE HEALTH AND SAFETY ACT)
AND REGULATION 8(2) OF
THE ELECTRICAL MACHINERY REGULATIONS OF THE OCCUPATIONAL HEALTH AND SAFETY ACT

CCG Cable Terminations (Pty) Ltd
P O Box 192
KEMPTON PARK
1620

5 July 2002

**IA CERTIFICATE
CABLE GLAND - EX CORROSION GUARD**

Description: The "EX Corrosion Guard" range of "Ex de IIC" Cable Glands for armoured cables each comprising of a metallic body, an inner seal, a space/cone element with a spring retaining ring, a rear seal and a corrosion guard body and outer nut. The glands are available with Metric (from M20 to M75) entry threads.

Marking: Each unit shall be marked with at least the following engravings:

Manufacturer	: CCG
SABS Permit	: Logo and Permit number
Type	: EX CORROSION GUARD
Size	: -----
IA No	: SABS S/W452UX
Symbol	: DIP/Ex de IIC T6

X - Special conditions of safe use: Not for use on Ex d enclosures larger than 2000cm² volume in Group IIC gases in Zone 1 Areas.

U - Incomplete assembly: The glands must be used as part of a certified assembly in Surface Installations only.


Compliance: The units as described above and tested/examined in SABS letter ref: 7234/W426 are hereby certified "Explosion Protected" DIP/Ex de IIC T6, and are suitable for use in hazardous locations as stated below, as determined during tests and inspections conducted in accordance with the relevant requirements of SABS Standards:

SABS 1213 1984 (1994) / SABS 1031:1994 / SABS IEC 60079-0:2000 / SABS IEC 60079-1:2001 / SABS IEC 60079-7:2001 / SABS IEC 60529:1989 / SABS IEC 61241.4.2000

Locations	Zone 1 / 2 and 21 / 22	Gas and Dust : Surface
Hazard Frequency		Intermittent as could occur under normal operating conditions in a hazardous area
Environment	Groups IIA, IIB, IIC	Propane to Acetylene
Limiting Temperature	T6	
Ingress Protection Rating		IP 66/68

The use of the apparatus in hazardous locations is subject to the following provisions, which shall be adhered to:

- i) SABS 086 requirements;
- ii) Any relevant requirements of the MHS Act or the OHS Act;
- iii) Codes of Practice enforced in terms of Regulations 21.17.2 of the Minerals Act, by the Chief Inspector of Mines;
- v) Any restrictions and conditions enforced by the Chief Inspector of Mines, Principal Inspector (Group I equipment) or Chief Inspector of Factories (Group II equipment).



**JG Gagiano: SENIOR TEST OFFICER
EXPLOSION PREVENTION TECHNOLOGY**



E Nqini: MANAGER

SABS COMMERCIAL (Pty) Ltd - Reg. No. 2000/013581/07 Website: www.sabs.co.za E-mail: info@sabs.co.za
Directors: Mr Martin Kuscus, Ms Cremilde Guedes, Ms Bronwen Phillips, Dr John Carstens, Dr Nombasa Tsengwa

Gauteng Head Office
1 Dr Lategan Road Groenkloof
Private Bag X191 Pretoria 0001
Tel: +27 (0) 12 428-7911
Fax: +27 (0) 12) 344-1568

Western Cape:
Liesbeek Park Way Rosebank Cape Town
PO Box 615 Rondebosch Cape Town 7701
Tel: +27 (0) 21 689-5511
Fax: +27 (0) 21 686-6375

Eastern Cape:
30 Kipling Road (cnr. Diaz and Kipling Roads)
PO Box 3013 North End Port Elizabeth 6056
Tel: +27 (0) 41 391-8400
Fax: +27 (0) 41 391-8427

Kwazulu Natal:
15 Garth Road Waterfall Park
PO Box 30087 Mayville 4058
Tel: +27 (0) 31 203-2900
Fax: +27 (0) 31 203-2907