

SCREWFIT[®]

4-WAY JUNCTION BOX - IP66/68

for General Industrial and Mining Electrical Installations

Features and Benefits


- ScrewFit[®] 4-Way Box for general industrial and mining electrical installations.
- 20mm Box supplied complete with safety securing lid lanyard.
- Raised domed lid facilitates connections to be made outside of the box.
- Only approved CCG cable glands and terminals must be used.
- No exposed metal parts.
- Dust and waterproof to IP66/68, when used with CCG sealed cable glands.
- No drilling or tapping of cable entries required.
- Mounting studs provided for DIN rail if using Terminal Blocks.
- Internal earthing to all entries and rail provided.
- ScrewFit[®] 4-Way Box can be buried for extended periods.
- Red Fire Rated Box for emergency circuits available (925°C for 3-hours).

Technical Data

Type:	ScrewFit [®] 4-Way Box	
Box Material:	Impact, corrosion and UV resistant glass reinforced polyester compound	
Optional Accessories:	Certified Terminals, Box Spanner (Lid Locking Key). Blanking plugs are provided	

Standards and Certifications

Service Temperature:	-60°C to +110°C (Unfinished)	
Conformance:	Standard:	Certificate:
IEC/BS/EN	62208:2011	CML 17Y11251
SANS	62208:2012	MASC 16-1787
Impact Protection IK10	IEC/BS/EN 62262	CML 17Y11251
IP66/68 Protection	IEC/BS/EN 60529	CML 17Y11251
	SANS 60529	MASC 16-1787
Deluge Protection	DTS 01	CML 14CA370-1
Marine Approvals ABS	IEC 60529	ABS 20-SG1952738-PDA
	DNV-GL	IEC 60529
		DNV-GL TAE0000011
Short Circuit Protection	IEC 60947-7-2, IEC 62444	CATAPULT OR/15/11677_2
Continuous Current Protection	IEC 60947-7-2	CATAPULT OR/15/11677_2
UV Protection	ISO 4892-2	
Zero Halogen	BS7211, BS 50267-2-1	TDW69-09-14
Flammability	UL94V-0	
London Underground Approval	IEC 62208, IEC 62262	LU 3057



Conditions for safe use

- Only the terminal blocks as per the description may be utilised in the junction box. Specific installation conditions as set by the terminal manufacturer/terminal certification must be considered. This includes considering the use of the applicable partitions and end plates for terminal blocks, conductor installation, tightening down of terminal block screws etc.
- Terminal blocks may only be utilised on the applicable rail and must allow sufficient space to make connections and to close the cover/lid.
- IP66/68 glands/plugs must be used in the threaded entries.
- Information in relation to entries is indicated in the instructions.

Product Code	Entry Thread 'A'	Distance Between Inserts 'C'	Mounting Centres 'D'	Rail Mounting Centres 'E'	Outer Diameter 'F'	Overall Height 'G'
065001-M16-SF	M16	88.0	92.0	80.0	118.0	98.0
065001-SF	M20	88.0	92.0	80.0	118.0	98.0
065002-M16-SF	M16	108.0	107.0	98.0	140.0	114.0
065002-M20-SF	M20	108.0	107.0	98.0	140.0	114.0
065002-SF	M25	108.0	107.0	98.0	140.0	114.0

All dimensions are in mm.

Wiring and installation instructions for SrewFit® 4-Way Box with components

- Installation must be carried out by a competent person.
- Do not install under live current conditions.
- The box must not be modified in any way, as may compromise the integrity of the boxes.
- All wiring must be carried out in accordance with the relevant Codes of Practice.
- The wiring insulation must not extend by more than 1.0mm from the metal face of the terminal as shown in Figure 1.
- The voltage and current value of the terminals in Table 2 must not be exceeded.
- Only those terminals shown in the terminal schedule may be incorporated in the box, refer Table 1.
- Inner cable bedding must protrude into the box by a minimum of 20mm past the cable entry point.
- Not more than one single or multiple strand lead shall be connected to either side of the terminals.
- Only earth conductors of equal size shall be connected with rail mounted terminals.
- All terminal screws used and unused shall be tightened.
- A parallel shaft screwdriver of the correct size should be used for rail mounted terminals screws.
- Where cables enter the box they must be secured by CCG Cable Glands appropriate to the makeup of the cable.
- Unused entry apertures must be blanked with CCG Standard Blanking Plugs.
- To maintain IP66/68 a thread seal gasket between the box and cable gland must be installed.
- Before replacing the lid, ensure the lid gasket is in place.

TABLE 1

Box Type	Box Size	Terminal Type and Size	Max Quantity	Rail Size
ScrewFit® 4 Way	1	2.5mm ²	12	35
ScrewFit® 4 Way	1	4mm ² mini terminal	11	15
ScrewFit® 4 Way	1	4mm ²	11	35
ScrewFit® 4 Way	1	6mm ²	9	35
ScrewFit® 4 Way	1	10mm ²	7	35
ScrewFit® 4 Way	1	16mm ²	5	35
ScrewFit® 4 Way	2	2.5mm ²	16	35
ScrewFit® 4 Way	2	4mm ² mini terminal	14	15
ScrewFit® 4 Way	2	4mm ²	13	35
ScrewFit® 4 Way	2	6mm ²	11	35
ScrewFit® 4 Way	2	10mm ²	8	35
ScrewFit® 4 Way	2	16mm ²	7	35
ScrewFit® 4 Way	2	35mm ²	5	35


TABLE 2

VOLTAGE PER TERMINAL CONFIGURATION

Terminals	Volt	Earth Terminals
AKZ 4	275V	AKE 4
WDU 2.5	550V	WPE 2.5
WDU 4	550V	WPE 4
WDU 6	550V	WPE 6
WDU 10	550V	WPE 10
WDU 16	550V	WPE 16
WDU 35	550V	WPE 35
WDU 70 N	550V	WPE 70 N


Tools /Accessories for general, industrial and mining electrical installations

Pole Mounting Bracket



Product Code	Box Size Reference
401800	M20
401801	M20
401802	M25


Non Metallic Plugs IP66/68 complete with washer




Product Code	Metric Dia 'A'	Dia Max 'B'	Dia Max 'C'	Dia Min 'D'	Hex Size Max A/F	Torque Value Nm
352820	M20x1.5	5.0	28.0	12.0	10.0	7.0
352825	M25x1.5	5.0	33.0	15.0	10.0	9.0



TS 15 Mini Rail



Mini Terminals for conductor sizes 0.5 to 4mm²



Insulated Terminal Connector 0.5mm to 16mm

FIGURE 1

The wiring insulation must not extend by more than 1.0mm from the metal face of the terminal as shown below.

