



IECEX Certificate of Conformity

INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification System for Explosive Atmospheres

for rules and details of the IECEx Scheme visit www.iecex.com

Certificate No.: **IECEX TSA 22.0011X** Page 1 of 4 [Certificate history:](#)
Status: **Current** Issue No: 0
Date of Issue: 2022-08-26
Applicant: **CCG Cable Terminations PTY LTD**
33-37 Forge Road
Spartan Industrial Area, Kempton Park 1619
South Africa
Equipment: **Range of cable glands for armoured and non-armoured cables**
Optional accessory: See Equipment Schedule for details
Type of Protection: **Flameproof "db", Increased Safety "eb", Restricted Breathing "nR", Dust Ignition "ta"**
Marking: Ex db I Mb / Ex db IIC Gb
Ex eb I Mb / Ex eb IIC Mb
Ex nR IIC Gc
Ex ta IIC Da
Refer to Equipment description for details
IP 66/67/68 (2m) or IP65 (as applicable)

Approved for issue on behalf of the IECEx
Certification Body:

Ujen Singh

Position:

Quality & Certification Manager

Signature:
(for printed version)

Date:
(for printed version)

26 August 2022

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting www.iecex.com or use of this QR Code.



Certificate issued by:

TestSafe Australia
919 Londonderry Road
Londonderry NSW 2753
Australia





IECEX Certificate of Conformity

Certificate No.: **IECEX TSA 22.0011X**

Page 2 of 4

Date of issue: 2022-08-26

Issue No: 0

Manufacturer: **CCG Cable Terminations Pty Ltd**
33-37 Forge Road
Spartan Ind Area
Kempton Park, 1619
South Africa

Manufacturing locations: **CCG Cable Terminations Pty Ltd**
33-37 Forge Road
Spartan Ind Area
Kempton Park, 1619
South Africa

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended

STANDARDS :

The equipment and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards

[IEC 60079-0:2017](#) Explosive atmospheres - Part 0: Equipment - General requirements
Edition:7.0

[IEC 60079-1:2014-06](#) Explosive atmospheres - Part 1: Equipment protection by flameproof enclosures "d"
Edition:7.0

[IEC 60079-15:2017](#) Explosive atmospheres - Part 15: Equipment protection by type of protection "n"
Edition:5.0

[IEC 60079-31:2013](#) Explosive atmospheres - Part 31: Equipment dust ignition protection by enclosure "t"
Edition:2

[IEC 60079-7:2017](#) Explosive atmospheres - Part 7: Equipment protection by increased safety "e"
Edition:5.1

This Certificate **does not** indicate compliance with safety and performance requirements other than those expressly included in the Standards listed above.

TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in:

Test Reports:

[GB/CML/ExTR18.0020/00](#)
[GB/CML/ExTR19.0171/00](#)
[GB/CML/ExTR21.0087/00](#)

[GB/CML/ExTR18.0269/00](#)
[GB/CML/ExTR20.0126/00](#)
[GB/CML/ExTR22.0046/00](#)

[GB/CML/ExTR19.0094/00](#)
[GB/CML/ExTR20.0189/00](#)

Quality Assessment Report:

[ZA/ICS/QAR14.0001/07](#)



IECEX Certificate of Conformity

Certificate No.: **IECEX TSA 22.0011X**

Page 3 of 4

Date of issue: 2022-08-26

Issue No: 0

EQUIPMENT:

Equipment and systems covered by this Certificate are as follows:

Cable glands for use with armoured cables, Types; E1EX (VS)(QS)(VX), E1EX-U (VS)(QS)(VX), E1EX Lead Seal, D1EX (QS)(VX), CXe, CWe, EXCG (VS)(QS)(VX), VRTX SWA, FLP (QS)(VX), ARMORTEX (QS)(VX), EXCG-Lead Seal, UNITEx-D (VS), UNITEx-E, UNITEx-QS (VX), UNITEx-F, UNITEx-F~QS(VX), TMC, TMCX.

Cable glands for use with non-armoured and braid cables, Types; FLP-TR (QS)(VX), FLP-TR- KHDE (QS)(VX), FLPHOSE (QS)(VX), Posi Grip (QS)(VX), A2EX (VS)(QS)(VX), A2EX-FHC (VS)(QS)(VX), VRTX, A2F-FHC-QS (VX).

Refer to Annex for full description.

SPECIFIC CONDITIONS OF USE: YES as shown below:

The following conditions relate to safe installation and/or use applicable to all models.

- i. The cable glands shall only be used where the temperature, at the point of entry, is between:
 - Posigrip: -30% glass filled polyester (-20°C and +95°C) or nylon (-60°C to 100°C)
 - Quickstop or Vortex resin type S50 / EPA, when used with any gaskets/skid rings: (-50°C and +95°C)
 - Quickstop or Vortex resin type FR/846, when used with EPDM seals & Nylon gaskets/skid rings or Silicone seals & PTFE gaskets / skid rings: - (-60°C and +100°C)
 - EPDM seals & HDPE gaskets/skid rings: (-60°C and +95°C)
 - EPDM seals & Nylon gaskets/skid rings: (-60°C and +100°C)
 - Silicone seals & PTFE gaskets/skid rings: (-60°C and +160°C)
 - The corrosion guard is not an essential part of the explosion protection. The corrosion guard material has a Relative Temperature Index (RTI) of 120°C.
- ii. Only the compounds as supplied by the manufacturer shall be used in the glands.
- iii. Cable glands for unarmoured or braided cable and approved only for Group IIC/IIIC (Not Group I) shall only be used on fixed installations where the cable is clamped, or stress applied to the cable in the gland is prevented.
- iv. When constructed of aluminium, the glands shall not be used in Group I applications.
- v. When the RE-FLEx sealing method is used, the gland installer shall refer to the manufacturer's instructions.

The following conditions relate to safe installation and/or use applicable to specific models.

- vi. VRTX range of glands:
 - The VRTX range of cable glands shall only be used on fixed installations where the cable is clamped, or stress applied to the cable in the gland is prevented
- ii. Armortex and E1EX-U type ranges of glands
 - The Armortex and E1EX-U type glands have been tested for braided cable for Group II and III only, when braided cable is fitted it shall only be used on fixed installations where the cable is clamped or stress applied to the cable in the gland is prevented.
- iii. Posi grip range of glands:
 - The gland shall only be installed / dismantled using the tool provided by CCG.



IECEX Certificate of Conformity

Certificate No.: **IECEX TSA 22.0011X**

Page 4 of 4

Date of issue: 2022-08-26

Issue No: 0

**Additional information:
Conditions of Manufacture**

The following conditions are required of the manufacturing process for compliance with the certification:

1. Cable glands with intermediate metric entry thread sizes shall be constructed by enlarging the entry thread size of the standard size product immediately below the intermediate thread size. The minimum entry wall thickness, allowable number of cores, cable size range and constructional parts utilised (other than the entry thread component) shall not differ from that of the standard size used.
2. When constructed of aluminium, the glands shall not be marked for Group I applications.

Annex:

[IECEX TSA 22.0011X-0_Annexe_1.pdf](#)



IECEX Certificate of Conformity Annexe

Annexe for Certificate No.:	IECEX TSA 22.0011X	Issue No.:	0
------------------------------------	--------------------	-------------------	----------

Equipment description continue:

Cable glands for use with armoured cables, Types; E1EX (VS)(QS)(VX), E1EX-U (VS)(QS)(VX), E1EX Lead Seal, D1EX (QS)(VX), CXe, CWe, EXCG (VS)(QS)(VX), VRTX SWA, FLP (QS)(VX), ARMORTEX (QS)(VX), EXCG-Lead Seal, UNITEx-D (VS), UNITEx-E, UNITEx~QS (VX), UNITEx-F, UNITEx-F~QS(VX), TMC, TMCX.

Cable glands for use with non-armoured and braid cables, Types; FLP-TR (QS)(VX), FLP-TR- KHDE (QS)(VX), FLPHOSE (QS)(VX), Posi Grip (QS)(VX), A2EX (VS)(QS)(VX), A2EX-FHC (VS)(QS)(VX), VRTX, A2F-FHC-QS (VX).

Product	Sizes	Ex db IIC Gb	Ex eb IIC Gb	Ex db I Mb	Ex eb I Mb	Ex ta IIC Da
ARMORTEX (QS)(VX)	00-7 (Metric & NPT)	✓	✓	✓	✓	✓
E1EX U (VS)(QS)(VX)	00-10 (Metric & NPT)	✓	✓	✓	✓	✓
FLP (QS)(VX)	00-7 (Metric & NPT)	✓	✓	✓	✓	✓
FLP Hose (QS)(VX)	00-7 (Metric & NPT)	✓	✓	✓	✓	✓
FLP TR (QS)(VX)	00-7 (Metric & NPT)	✓	✓	✓	✓	✓
FLP-TR-KHDE (QS)(VX)	00-7 (Metric & NPT)	✓	✓	✓	✓	✓
A2EX (VS) (QS)(VX)	00-13 (Metric &NPT)	✓	✓			✓
A2EX-FHC (VS) (QS)(VX)	00-13 (Metric) 0-11 (NPT)	✓	✓			✓
A2F-FHC~ QS (VX)	00-10 (Metric) 0-10 (NPT)	✓	✓			✓
D1EX (QS)(VX)	00-13 (Metric) 00-11 (NPT)	✓	✓			✓
E1EX (VS)(QS)(VX)	00-13 (Metric) 00-11 (NPT)	✓	✓			✓
E1EX Lead Seal	00-13 (Metric) 00-11 (NPT)	✓	✓			✓
EXCG (VS)(QS)(VX)	00-10 (Metric)	✓	✓			✓
EXCG – Lead Seal	00-13 (Metric)	✓	✓			✓
Posi Grip (QS)(VX)	00-11 (Metric)	✓	✓			✓
UNITEx-D (VS)	00-10 (Metric & NPT)	✓	✓			✓
UNITEx ~QS(VX)	00-10 (Metric & NPT)	✓	✓			✓
UNITEx~F~ QS(VX)	00-10 (Metric & NPT)	✓	✓			✓
TMCX	00-11 (Metric & NPT)	✓	✓			✓
CXe	00-13 (Metric) 00-11 (NPT)		✓			✓
CWe	00-13 (Metric) 00-11 (NPT)		✓			✓
TMC	00-11 (Metric & NPT)		✓			✓
UNITEx-E	00-10 (Metric & NPT)		✓			✓
UNITEx-F	00-10 (Metric & NPT)		✓			✓
VRTX	0-8 (Metric)		✓			✓
VRTX SWA	0-8 (Metric)		✓			✓

Notes:

1. Cable glands with parallel entry threads are IP66/68 when fitted with the supplied sealing gasket. NPT threads are at least IP65 as standard, but IP68 (2m) can be achieved if one of the following grease types is applied to the NPT thread before fitting:- Renolit Lubrene CA 700, Renolit LC-WP2, Renolit Lubrene LX 220 EP2, Renolit Moly LX 2 or Dow Corning 4 Electrical Compound.

Certificate issued by:

	<p style="margin: 0;">TestSafe Australia 919 Londonderry Road Londonderry NSW 2753 Australia</p>
---	---



IECEX Certificate of Conformity Annexe

Annexe for Certificate No.:	IECEX TSA 22.0011X	Issue No.:	0
------------------------------------	--------------------	-------------------	----------

- Cable glands with parallel entry threads (e.g. Metric and BSP parallel) are supplied with fitted sealing gaskets as standard. The sealing gasket is optional for Ex d applications without IP rating. (RE-FLEx cord may be used as an alternative to a standard sealing gasket).
- 'VS' in the name of a cable gland variant indicates that a thin copper/brass disc is fitted between the inner seal and the cone for earth continuity to a metallic cable screen (e.g. variable speed drive cable or a lead sheathed cable). The sealing arrangement between the inner seal and the potted sleeve is not affected. Note that a standard cable gland type can be converted to a (VS) variant by retrofitting the thin copper / brass disc. The product marking does not need to be changed when the copper / brass disc is retrofitted.
- '-FC' in the name of a cable gland variant indicates that the outer seal nut has an additional female thread to allow the connection of a flexible conduit.
- 'QS' in the name of a cable gland variant, indicates that it is the Quickstop resin barrier version of the cable gland. This utilises a clear potting compound to achieve a hard setting seal inside the gland. The sealing compound is transparent and accommodates inspection.
- 'VX' in the name of a cable gland variant, refers to the Vortex resin barrier version of the cable gland. This utilises a coloured potting compound to achieve a hard setting seal inside the gland. There is a transparent elastomeric seal at the end of the compound enclosure to accommodate inspection.
- Cable glands that are available as both barrier (QS or VX) and non-barrier versions may be supplied as non-barrier versions together with the additional components needed to convert them to barrier versions if required. When the conversion is carried out the product marking does not need to be changed.
- RE-FLEx sealing cord can be used as an alternative to a standard sealing gasket to achieve IP66/68. It is intended as a retro-fit solution and must be installed according to the fitting instructions supplied with it.


Materials of Manufacture

- Brass (CZ121), Bronze (PB2), Stainless Steel (316), Aluminium (6063), Mild steel (EN8)
- HDPE (D7255/HL), PTFE (CCG PTFE-001), Nylon (6)
- EPDM (64 Shore), Silicone (CCG G/65-1C)
- QuickStop Ex resin (S50/EPA or FR/846), VORTEX Ex resin (S50/Y, EPA/Y or FR/846/Y)

Drawing list pertaining to Issue 0 of this Certificate:

Document / Drawing Number:	Page/s:	Title:	Revision Level:	Date: (yyyy-mm-dd)
0468 ASSY	1 of 1	*No. "X" A2F-FHC~QS GLAND ASSY.	1	2020-04-28
0468-I METRIC	1 of 1	*A2F-FHC~QS INNER - METRIC	-	2020-06-11
0468-I NPT	1 of 1	*A2F-FHC~QS INNER - NPT	-	2020-06-11
0468-O	1 of 1	*A2F-FHC~QS OUTER	-	2020-06-11

Certificate issued by:

	TestSafe Australia 919 Londonderry Road Londonderry NSW 2753 Australia
---	---




IECEX Certificate of Conformity Annexe

Annexe for Certificate No.:	IECEX TSA 22.0011X	Issue No.:	0
------------------------------------	--------------------	-------------------	----------

Document / Drawing Number:	Page/s:	Title:	Revision Level:	Date: (yyyy-mm-dd)
0468-S	1 of 1	*A2F-FHC~QS RESIN SLEEVE	-	2020-06-11
0468-SP	1 of 1	*A2F-FHC~QS SPACER	-	2020-06-11
0503 - C	1 of 1	*No. "X" BW CONE	-	2018-03-20
0510-ASSY	1 of 1	*No. "X" UNITEx-F GLAND ASSY	5	2021-04-14
0519 - O	1 of 1	*No. "X" D1EX OUTER	1	2018-03-20
0519-ASSY	1 of 1	*No. "X" D1EX Ex de CABLE GLANDS	6	2022-04-28
0521- ASSY	1 of 1	*No. "X" FLP GLAND ASSEMBLY	5	2022-04-28
0521-C	1 of 1	*No. "X" FLP CONE	-	2018-03-20
0521 -I- LN	1 of 1	*No. "X" FLP, FLP TR, FLP HOSE, ARMORTEX INNER LOCK NUT	-	2018-03-20
0521-IS	1 of 1	*No. "X" FLP, FLP TR, FLP HOSE, ARMORTEX INNER SEAL	-	2018-03-20
0521-CR	1 of 1	*No. "X" FLP CONE RING	-	2018-03-20
0521-FC-C	1 of 1	*No. "X" FLP-FC CONE	-	2022-04-28
0521-I	1 of 1	*No. "X" FLP, FLP-TR, FLP HOSE & ARMORTEX INNER	2	2018-03-20
0521-O	1 of 1	*No. "X" FLP OUTER	-	2018-03-20
0522 - B	1 of 1	*No. "X" ARMORTEX BODY	-	2018-03-20
0522- ASSY	1 of 1	*No. "X" ARMORTEX GLAND ASSEMBLY	5	2022-04-28
0522-ON	1 of 1	*No. "X" ARMORTEX OUTER NUT	-	2018-03-20
0523 ASSY	1 of 1	*No. "X" E1EX Ex de CABLE GLANDS	5	2020-06-11
0523 – ASSY-QS	1 of 1	*No. "X" E1EX QUICK STOP ASSY	2	13/05/2019
0523-B	1 of 1	*No. "X" EXCG BODY	4	2020-06-11
0523-C	1 of 1	*No. "X" D1EX & EXCG CONE	2	2020-06-11
0523 - CR	1 of 1	*No. "X" E1EX, D1EX, EXCG, STOPEX & STOPEX CG CONE RING	1	2018-03-20
0523-I	1 of 1	*No. "X" A2EX, A2EX-FHC, D1EX & EXCG INNER	4	2020-06-11
0523 - IS	1 of 1	*No"X" E1EX, A2EX, EXCG, A2EX FHC & D1EX INNER/DISPLACEMENT SEAL	1	2018-03-20
0523 – NPT - I	1 of 1	*No. "X" A2EX, D1EX, A2EX FHC & EXCG INNER	2	2020-06-11
0523 - ON	1 of 1	*No. "X" E1EX OUTER NUT	1	2018-03-20
0523 - OS	1 of 1	*No. "X" E1EX OUTER SEAL	1	2018-03-20
0523 - SR	1 of 1	*No. "X" EXCG SKID RING	1	2018-03-20
0523 D - B	1 of 1	*No. "X" E1EX BODY	1	2022-04-28
0523 D-I	1 of 1	*No. "X" E1EX INNER	1	2022-04-28

Certificate issued by:

	<p style="margin: 0;">TestSafe Australia 919 Londonderry Road Londonderry NSW 2753 Australia</p>
---	---



IECEX Certificate of Conformity Annexe

Annexe for Certificate No.:	IECEX TSA 22.0011X	Issue No.:	0
------------------------------------	--------------------	-------------------	----------

Document / Drawing Number:	Page/s:	Title:	Revision Level:	Date: (yyyy-mm-dd)
0523 D – NPT - I	1 of 1	*No. "X" E1EX INNER	-	2020-06-11
0523 –LS- I	1 of 1	*No. "X" E1EX LEAD SEAL INNER	-	2018-03-20
0523 – ASSY - SL	1 of 1	*TYPICAL QUICK STOP WITH SLEEVE ASSEMBLY	4	2018-03-20
0523L ASSY	1 of 1	*No "X" E1EX COMBINATION GLAND ASSY.	-	2020-06-11
0523-LS ASSY	1 of 1	*No. "X" E1EX LEAD SEAL ASSY	5	2022-04-28
0523-LS	1 of 1	*No. "X" E1EX LEAD SEAL	-	2018-03-20
0524- O	1 of 1	*No. "X" FLP TR OUTER	-	2018-03-20
0524 – ASSY	1 of 1	*No. "X" FLP TR ASSEMBLY	5	2018-03-20
0524-C -OR	1 of 1	*No. "X" FLP TR ASSEMBLY	-	2018-03-20
0524-FC ASSY	1 of 1	*No. "X" FLP-TR-FC FLEXIBLE CONDUIT ASSEMBLY	-	2022-04-28
0524-FC-O	1 of 1	*No. "X" FLP-TR-FC OUTER	-	2022-04-28
0524-GS	1 of 1	*No. "X" FLP TR GRIPPER SEAL	-	2018-03-20
0524-KHDE-ASSY	1 of 1	*No. "X" FLP-TR-KHDE GLAND ASSEMBLY	-	2022-04-28
0524-O-D	1 of 1	*No. "X" FLP TR DIESEL OUTER	-	2022-04-28
0524-SR	1 of 1	*No. "X" FLP TR SKID RING	-	2018-03-20
0525-ON	1 of 1	*No. "X" BARRIER A OUTER NUT	-	2018-03-20
0525-OS	1 of 1	*No. "X" BARRIER A OUTER SEAL	-	2018-03-20
0525-SR	1 of 1	*No. "X" BARRIER A SKID RING	-	2018-03-20
0527- HOSE ASSY	1 of 1	*FLP HOSE GLAND ASSEMBLY	5	2022-04-28
0527-FC-ASSY	1 of 1	*No. "X" FLP-FC FLEXIBLE CONDUIT GLAND ASSEMBLY	-	2022-04-28
0527-FC-O	1 of 1	*No. "X" FLP-FC OUTER	-	2022-04-28
0527- HT	1 of 1	*No. "X" FLP HOSE TAIL	-	2018-03-20
0531- SG	1 of 1	*No. "X" SEALING GASKET	-	2018-03-20
0531-ON	1 of 1	*No. "X" OUTER NUT	-	2018-03-20
0531 –B - SWA	1 of 1	*No. "X" VRTX BODY SWA	-	2018-03-20
0531- B	1 of 1	*No. "X" VRTX BODY	-	2018-03-20
0531-CN -SWA	1 of 1	*No. "X" VRTX- SWA- COMPRESSION NUT	-	2018-03-20
0531-CN	1 of 1	*No. "X" VRTX COMPRESSION NUT	1	2018-03-20
0531-I -SWA	1 of 1	*No. "X" VRTX INNER	1	2021-04-14
0531-I	1 of 1	*No. "X" VRTX INNER	1	2018-03-20
0531-OS	1 of 1	*No. "X" OUTER SEAL	-	2018-03-20
0531-SR	1 of 1	*No. "X" SKID RING	-	2018-03-20

Certificate issued by:

	<p style="margin: 0;">TestSafe Australia 919 Londonderry Road Londonderry NSW 2753 Australia</p>
---	---



IECEX Certificate of Conformity Annexe

Annexe for Certificate No.:	IECEX TSA 22.0011X	Issue No.:	0
------------------------------------	--------------------	-------------------	----------

Document / Drawing Number:	Page/s:	Title:	Revision Level:	Date: (yyyy-mm-dd)
0531-SWA-ASSY	1 of 1	*No. "X" VRTX – SWA GLAND ASSEMBLY	3	2020-06-11
0531-VRTX SPRING	1 of 1	*No. "X" VRTX SPRING DETAIL	-	2018-03-20
0531-VRTX	1 of 1	*No. "X" VRTX GLAND ASSEMBLY	4	2022-04-28
0536 - C	1 of 1	*No. "X" A2EX & POSI GRIP CONE	4	2018-03-20
0536 - O	1 of 1	*No. "X" A2EX OUTER	7	2018-03-20
0536-ASSY	1 of 1	*No. "X" A2EX ASSEMBLY	9	2022-04-28
0537 - ASSY	1 of 1	*No. "X" A2EX FHC GLAND ASSEMBLY	6	2022-04-28
0537 - C	1 of 1	*No. "X" A2EX & POSI GRIP CONE	3	2018-03-20
0537 - CO	1 of 1	*No. "X" A2EX-FHC COUPLING	-	2018-03-20
0537 - O	1 of 1	*No. "X" A2EX-FHC OUTER	-	2018-03-20
0537 - OC	1 of 1	*No. "X" A2EX-FHC OUTER COUPLING	-	2018-03-20
0537 - SR	1 of 1	*No. "X" A2 SKID RING	5	2018-03-20
0537 - GS	1 of 1	*No. "X" A2 GRIPPER SEAL	6	2012-08-21
0545 - ASSY	1 of 1	*No. "X" POSI GRIP ASSEMBLY	4	2022-04-28
0545 - NS	1 of 1	*No. "X" POSI GRIP NIPPLE SEAL	-	2018-03-20
0545 – O- ASSY	1 of 1	*No. "X" POSI GRIP OUTER ASSEMBLY	-	2018-03-20
0545 I- ASSY	1 of 1	*No. "X" POSI GRIP INNER ASSY	-	2018-03-20
0547 - ASSY	1 of 1	*No. "X" Ex de CORROSION GUARD	7	2022-04-28
0547 - CGSG	1 of 1	*No. "X" EXCG SEALING GASKET	-	2018-03-20
0547 - OS	1 of 1	*No. "X" EXCG OUTER SEAL	1	2018-03-20
0547- CG- LS- ASSY	1 of 1	*No. "X" EXCG LEAD SEAL ASSY	3	2022-04-28
0547-BODY-ASSY	1 of 1	*No "X" EXCG BODY COMPONENTS	2	2018-11-20
0554-ASSY	1 of 1	*No. "X" UNITEx-D GLAND ASSY	6	2021-04-14
0554-B	1 of 1	*No. "X" UNITEx-D BODY	3	2021-04-14
0554-C	1 of 1	*No "X" UNITEx-D CONE	2	2019-08-21
0554-I	1 of 1	*No "X" UNITEx-D INNER	1	2019-08-21
0554L-ASSY	1 of 1	*No. "X" UNITEx-D COMBINATION GLAND ASSY	1	2021-04-14
0554-ON	1 of 1	*No "X" UNITEx-D OUTER NUT	2	2019-08-21
0559-ASSY	1 of 1	*No. "X" UNITEx~QS GLAND ASSY	6	2022-04-28
0559-B	1 of 1	*No. "X" UNITEx~QS BODY	-	2019-08-21
0559-C	1 of 1	*No. "X" UNITEx~QS CONE	-	2019-08-21
0559-I	1 of 1	*No. "X" UNITEx~QS INNER	-	2019-08-21

Certificate issued by:

	<p style="margin: 0;">TestSafe Australia 919 Londonderry Road Londonderry NSW 2753 Australia</p>
---	---




IECEX Certificate of Conformity Annexe

Annexe for Certificate No.:	IECEX TSA 22.0011X	Issue No.:	0
------------------------------------	--------------------	-------------------	----------

Document / Drawing Number:	Page/s:	Title:	Revision Level:	Date: (yyyy-mm-dd)
0560-IS	1 of 1	*No. "X" E1EX~QS INNER SEAL	-	2018-03-20
0571 - B	1 of 1	*No. "X" E1EX UNIVERSAL BODY	2	2018-03-20
0571 - C	1 of 1	*No. "X" E1EX UNIVERSAL CONE	-	2018-03-20
0571 - CR	1 of 1	*No. "X" E1EX UNIVERSAL CONE RING	-	2018-03-20
0571 - IS	1 of 1	*No. "X" E1EX – U INNER SEAL	-	2018-03-20
0571 - NPT - I	1 of 1	*No. "X" E1EX UNIVERSAL INNER	-	2018-03-20
0571 - ASSY	1 of 1	*No. "X" E1EX UNIVERSAL GLAND ASSY	6	2022-04-28
0571 – I	1 of 1	*No. "X" E1EX UNIVERSAL INNER	1	2018-03-20
0571L – ASSY	1 of 1	*No. "X" E1EX UNIVERSAL COMBINATION GLAND ASSY	-	2020-06-11
0571-ON	1 of 1	*No. "X" E1EX UNIVERSAL OUTER NUT	1	2018-03-20
0571-OS	1 of 1	*No. "X" E1EX UNIVERSAL OUTER SEAL	-	2018-03-20
0571-SR	1 of 1	*No. "X" E1EX UNIVERSAL SKID RING	-	2018-03-20
0587-ASSY	1 of 1	*No. "X" UNITEx-F~QS GLAND ASSY	5	2021-04-14
0587-C	1 of 1	*No. "X" UNITEx-F~QS CONE	-	2018-03-20
0587-I	1 of 1	*No. "X" UNITEx-F~QS INNER	3	2021-04-14
0587-IS	1 of 1	*No. "X" UNITEx-F~QS INNER SEAL	-	2018-03-20
0587-S	1 of 1	*No. "X" UNITEx-F~QS RESIN SLEEVE	-	2018-03-20
0589 ASSY	1 of 1	*TMCX ASSEMBLY	-	2020-09-02
0589-ES	1 of 1	*TMCX END STOP	-	2020-09-02
0589-I	1 of 1	*TMCX INNER METRIC	-	2020-09-02
0589-I-NPT	1 of 1	*TMCX INNER NPT	-	2020-09-02
0589-S	1 of 1	*TMCX RESIN SLEEVE	-	2020-09-02
0591-ASSY	1 of 1	*No. "X" UNITEx-E GLAND ASSY	4	2020-06-11
0595 ASSY	1 of 1	*TMC ASSEMBLY	-	2020-09-02
0595-I	1 of 1	*TMC INNER - METRIC	-	2020-09-02
0595-I-NPT	1 of 1	*TMC INNER - NPT	-	2020-09-02
0595-ON	1 of 1	*TMC OUTER NUT	-	2020-09-02
0595-SP	1 of 1	*TMC SPACER	-	2020-09-02
8055 - SG	1 of 1	*No. "X" CCG SEALING GASKET	1	2021-04-14
055700-16-055713	1 of 1	*No. "X" CWe GLAND ASSEMBLY	4	2020-06-11
055700-16-I-055713-I	1 of 1	*No. "X" CWe / CXe INNER	2	2022-04-28
057000-16-057010	1 of 1	*No. "X" CXe GLAND ASSEMBLY	5	2021-04-14

Certificate issued by:

	<p>TestSafe Australia 919 Londonderry Road Londonderry NSW 2753 Australia</p>
---	--



IECEX Certificate of Conformity Annexe

Annexe for Certificate No.:	IECEX TSA 22.0011X	Issue No.:	0
------------------------------------	--------------------	-------------------	----------

Document / Drawing Number:	Page/s:	Title:	Revision Level:	Date: (yyyy-mm-dd)
057000-C-057010-C	1 of 1	*No. "X" CXe CONE	1	2018-03-20
057001 - 057004 - B	1 of 1	*No. "X" CXe BODY	1	2021-04-14
Marking Label Drawings				
0468 MARK AUS	1 of 1	*A2F-FHC~QS(VX) GLAND MARKING	0	2022-06-21
0521 – MARK AUS	1 of 1	*No. "X" FLP, ARMORTEX MARKING	0	2022-06-21
0523 – MARK AUS	1 of 1	*No. "X" EX GLAND MARKING	0	2022-06-20
0523- LS AND U MARK AUS	1 of 1	*No. "X" E1EX – LS AND – U GLAND MARKING	0	2022-06-20
0527-FC-MARK AUS	1 of 1	*FLP-FC, FLP-TR-FC & FLP-TR-KHDE MARKING	0	2022-06-20
0531-MARK AUS	1 of 1	*No."X" VRTX GLAND MARKING	0	2022-06-21
0537-MARK AUS	1 of 1	*A2EX-FHC GLAND MARKING	0	2022-06-21
0545- MARK AUS	1 of 1	*No. "X" POSI GRIP MARKING	0	2022-06-21
0557 -MARK AUS	1 of 1	*CWe / CXe GLAND MARKING	0	2022-06-20
0587-MARK AUS	1 of 1	*No. "X" UNITEX-F(QS) - MARKING	0	2022-06-20
0591-MARK AUS	1 of 1	*No. "X" UNITEX GLAND MARKING	0	2022-06-20
0595 – MARK AUS	1 of 1	*TMC / TMCX MARKING	0	2022-06-20

Note: An * is included before the title of documents that are new or revised

Certificate issued by:

	TestSafe Australia 919 Londonderry Road Londonderry NSW 2753 Australia
---	---