

CX/Z INSULATED

CAPTIVE COMPONENT GLAND®

for Braided and Steel Tape Cable



Features and Benefits

- For indoor and outdoor use.
- Gland is insulated from equipment to prevent system circulating currents.
- Freely rotating captive cone and inspectible cone ring, providing an armour clamp and earth bond without twisting the armouring.
- Patented disconnect armoured clamp system for ease of inspection.
- Provides a seal on the outer sheath of the cable sealing to IP65/66.
- Precision manufactured from high-quality brass (nickel plated) available in aluminium or stainless steel 316/316L on request.
- Complete with heavy-duty (nickel plated) locknut.




Technical Data

Type:	CX/Z Insulated
Gland Material:	Brass (Nickel Plated) BS 2874, EN 12164, Aluminium ASTM BS221 Stainless Steel 316/316L
Seal Material:	Thermoset Elastomer
Cable Type:	Braid, Steel Tape Armour
Armour Clamping:	Rotating Captive Cone and Inspectible Cone Ring
Sealing Area:	Outer Sheath
Optional Accessories:	Adaptor, Reducer, Earth Tag, Locknut, Serrated Washer and Shroud

Standards and Certifications

Mechanical Properties:	Impact Category 8 Anchorage Type C	
Continuous Operating Temp:	-65°C to +120°C	
Conformance:	Standard:	Certificate:
Design Standards	BS 6121:Part 1 IEC/BS EN 62444 SANS 62444 SANS 1213	CML 14CA364 CML 14CA364 MASC 11-303 MASC 18-2047, SANS 2109/4596
IP66 - Parallel	IEC 60529	MASC 11-263
Marine ABS	IEC 62444	ABS 20-SG1952694-PDA
DNV-GL	IEC 60529, BS 6121, IEC 62444	DNV-GL TAE000000Z
London Underground Approval	BS EN 62444	LU 3043



Installation Standards

- AS/NZS 3000
- BS 7430
- BS 6121-5
- IEC 60364-5-54
- BS 7671
- SANS 0142

Product Code	Gland Size Reference	Entry Thread		NPT Entry Thread		Cable Detail			Max Length 'E'	Braid/STA Thickness		Hexagonal Detail		Installation Torque Value Nm
		'C'	Min 'D'	'C'	Min 'D'	Max 'A'	Min 'B'	Max 'B'		Min 'F'	Max 'F'	Max 'Flats'	Max 'Crns'	
057600	00-20ss	M20x1.5	10	1/2/3/4	15	8.0	8.0	13.5	55.0	0.2	0.85	♦ 24.0	♦ 27.0	35.0
0576-0	0-20s	M20x1.5	10	1/2/3/4	15	12.0	11.5	16.0	55.0	0.2	0.90	♦ 24.0	♦ 27.0	35.0
057601	1-20	M20x1.5	10	1/2/3/4	15	13.5	14.5	20.5	55.0	0.2	1.25	27.0	30.0	35.0
057622	2s-25s	M25x1.5	10	3/4/1	15/19	17.5	16.0	24.5	60.0	0.2	1.25	35.0	39.0	50.0
057602	2-25	M25x1.5	10	3/4/1	15/19	17.5	20.5	26.5	60.0	0.2	1.25	35.0	39.0	50.0
057633	3s-32s	M32x1.5	10	1/1 1/4	19	24.0	23.0	30.5	65.0	0.2	1.40	42.0	47.0	70.0
057603	3-32	M32x1.5	10	1/1 1/4	19	24.0	26.5	33.5	65.0	0.2	1.40	42.0	47.0	70.0
057644	4s-40s	M40x1.5	15	1 1/4/1 1/2	19/21	34.0	30.0	39.5	65.0	0.3	1.40	52.0	59.0	90.0
057604	4-40	M40x1.5	15	1 1/4/1 1/2	19/21	34.0	33.0	42.5	65.0	0.3	1.40	52.0	59.0	90.0
057655	5s-50s	M50x1.5	15	1 1/2/2	21	42.5	34.0	47.5	75.0	0.4	1.40	65.0	73.0	100.0
057605	5-50	M50x1.5	15	1 1/2/2	21	42.5	42.5	52.5	75.0	0.4	1.40	65.0	73.0	100.0
057666	6s-63s	M63x1.5	15	2/2 1/2	21/30	55.5	45.5	60.5	85.0	0.4	1.50	80.0	90.0	120.0
057606	6-63	M63x1.5	15	2/2 1/2	21/30	55.5	52.5	65.5	85.0	0.4	1.50	80.0	90.0	120.0
057677	7s-75s	M75x1.5	15	2 1/2/3	30/32	68.0	57.0	72.5	105.0	0.4	1.50	96.0	108.0	120.0
057607	7-75	M75x1.5	15	2 1/2/3	30/32	68.0	65.5	78.0	105.0	0.4	1.50	96.0	108.0	120.0
057688	8s-80s	M80x2.0	20	3	32	72.5	65.0	77.5	125.0	2.5	1.60	96.0	108.0	120.0
057608	8-80	M80x2.0	20	3	32	72.5	78.0	82.0	125.0	2.5	1.60	96.0	108.0	120.0
057699	9s-90s	M90x2.0	20	3/3 1/2	32/33	81.5	73.0	86.5	145.0	3.0	1.60	110.0	124.0	120.0
057609	9-90	M90x2.0	20	3/3 1/2	32/33	81.5	82.0	91.0	145.0	3.0	1.60	110.0	124.0	120.0


All dimensions except NPT are in mm.

♦ When manufactured in Aluminium, Hex will be 27 Across Flats and 30 Across Corners.


CCGG reserves the right to make alterations to the technical data, dimensions, designs and products available without notice. The illustrations cannot be considered binding. Please contact CCGG for assistance.

CXZINS-PEG200820E


CX/Z INSULATED CAPTIVE COMPONENT GLAND®




1. For accurate sizing, use a CCG Dimension Tape **(A)** on the inner and outer cable sheath.




2. Remove the locknut **(1)**.




3. Remove the female insulator ring **(2)**. To maintain IP66/68 rating ensure the gasket **(3)** is in place.




4. Insert the male insulator entry **(4)** into the cable entry of the apparatus.




5. Screw the female insulator ring **(2)** back against the apparatus (maximum of 10mm thickness). Screw the locknut **(1)** back against the female insulator ring **(2)**.




6. Strip the cable outer sheath and pass the outer nut **(6)** and the body **(5)** over the cable.




7. Pass the cable end through the inner and splay the armour wires **(7)** over the cone **(8)**.



8. Tighten the body **(5)** onto the inner to lock the armour between the cone **(8)** and cone ring **(9)**.



9. Unscrew the body **(5)**. Check that the armour has locked between the cone **(8)** and cone ring **(9)**. (O-Ring on the cone ring **(9)** is sacrificial).



10. Tighten the body **(5)** onto the inner using a CCG Spanner **(10)**. Tighten the outer nut **(6)** to produce a moisture-proof seal by turning until the seal makes contact with the outer sheath of cable and make one full turn.