



# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No.: 2021312303000506

**Applicant** CCG Cable Terminations (Pty) Ltd  
**Address** 33-37 Forge Road, Spartan Industrial Area, Kempton Park 1619, South Africa  
**Manufacturer** CCG Cable Terminations (Pty) Ltd  
**Address** 33-37 Forge Road, Spartan Industrial Area, Kempton Park 1619, South Africa  
**Production Factory** CCG Cable Terminations (Pty) Ltd  
**Production Address** 33-37 Forge Road, Spartan Industrial Area, Kempton Park 1619, South Africa  
**Product** Junction Boxes  
**Model/Type** See annex  
**Ex marking** Ex e IIC T6 Gb, Ex tD A21 IP66/IP67/IP68 T70°C,  
Ex tD A22 IP66/IP67/IP68 T70°C  
**Reference Standards** GB3836.1-2010, GB3836.3-2010, GB12476.1-2013, GB12476.5-2013

**Certification mode** Type Test + Initial Factory Inspection + Post-Certification Surveillance

The product(s) is verified and certified according to CNCA-C23-01: 2019 *China Compulsory Certification Implementation Rule on Explosion Protected Electrical Product* and CNEX-C2301-2019 *Guideline of China Compulsory Certification Implementation Rule on Explosion Protected Electrical Product*.

See Annex for the detailed product information (6 pages)

Issued on: 2021-06-02

Valid to: 2026-06-01

The validity of this certificate is maintained through the regular supervision of the issuing authority during the validity period.

Where any discrepancy arises between the English translation and the original Chinese version, the Chinese version shall prevail.

Director:



Nanyang Explosion Protected Electrical Apparatus Research Institute Co.,Ltd.



<http://www.ccc-cnex.com>  
[ccc.china-ex.com](http://ccc.china-ex.com)

Add: No. 20, North Zhongjing Road, Nanyang, Henan, P. R. China P.C.: 473008  
Tel: 0377-63239734 Email: [ccc@cn-ex.com](mailto:ccc@cn-ex.com)

CN 0000699





# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

## (Annex)

No.: 2021312303000506

Page 1 of 6

**Product information:**

1. This certificate covers the following models:

- Detailed models refer to the following table:

The Junction boxes comprise of a non-metallic enclosure component CCC certified that is fitted with terminals, as detailed in the table below:

Type and size	Dimensions (Dia. x height)	Gland entry sizes(1.5m pitch)	Max. amount of terminals and size	Max. No. of cable gland entries and arrangement
Posi Fit / Tx box Size 0	100 x 78	M16-M20	9 x 4 mm <sup>2</sup> mini terminals, 12 x 2.5 mm <sup>2</sup> terminals or 12 x 2.5 mm <sup>2</sup> mini terminals	CCG Posi Fit 4 Way box - 4 entries positioned orthogonal around the side walls with multiple gland entry sizes
Posi Fit / Tx box Size 1	118 x 91	M16-M20	10 x 2.5 mm <sup>2</sup> , 8 x 4mm <sup>2</sup> , 6 x 6 mm <sup>2</sup> , 5 x 10 mm <sup>2</sup> , 4 x 16 mm <sup>2</sup> terminals or 8 x 4 mm <sup>2</sup> mini terminals	CCG Posi Fit 4 Way box - 4 entries positioned orthogonal around the side walls with multiple gland entry sizes
Posi Fit / Tx box Size 2	140 x 114	M16-M25	12 x 2.5 mm <sup>2</sup> , 10 x 4mm <sup>2</sup> , 8 x 6 mm <sup>2</sup> , 7 x 10 mm <sup>2</sup> , 6 x 16 mm <sup>2</sup> , 3 x 35 mm <sup>2</sup> terminals or 10 x 4 mm <sup>2</sup> mini terminals	CCG Posi Fit 4 Way box - 4 entries positioned orthogonal around the side walls with multiple gland entry sizes
Posi Fit / Tx box Size 3	203 x 142	M16-M32	20 x 2.5 mm <sup>2</sup> , 16 x 4mm <sup>2</sup> , 12 x 6 mm <sup>2</sup> , 12 x 10 mm <sup>2</sup> , 10 x 16 mm <sup>2</sup> , 6 x 35 mm <sup>2</sup> , 5 x 70 mm <sup>2</sup> terminals or 14 x 4 mm <sup>2</sup> mini terminals	CCG Posi Fit 4 Way box - 4 entries positioned orthogonal around the side walls with multiple gland entry sizes
Posi Fit / Tx box Size 4	298 x 186	M16-M40	46 x 2.5 mm <sup>2</sup> , 32 x 4mm <sup>2</sup> , 28 x 6 mm <sup>2</sup> , 23 x 10 mm <sup>2</sup> , 18 x 16 mm <sup>2</sup> , 14 x 35 mm <sup>2</sup> ,	CCG Posi Fit 4 Way box - 4 entries positioned orthogonal around the side

Issued on: 2021-06-02

Director:



Nanyang Explosion Protected Electrical Apparatus Research Institute Co.,Ltd.







# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

## (Annex)

No.: 2021312303000506

Page 2 of 6

			10 x 70 mm <sup>2</sup> terminals or 35 x 4 mm <sup>2</sup> mini terminals	walls with multiple gland entry sizes
Bottom entry angle box Size 1	118 x 98	M16-M20	8 x 4 mm <sup>2</sup> mini terminals	CCG Bottom entry angle Box – 3 entries positioned at the bottom of the box. One entry closest to the rim of the box and two entries to the base of the box
Bottom entry angle box Size 2	140 x 105	M16-M25	12 x 2.5 mm <sup>2</sup> , 10 x 4mm <sup>2</sup> , 8 x 6 mm <sup>2</sup> , 7 x 10 mm <sup>2</sup> terminals or 8 x 4 mm <sup>2</sup> mini terminals	CCG Bottom entry angle Box – 3 entries positioned at the bottom of the box. One entry closest to the rim of the box and two entries to the base of the box
Bottom entry angle box Size 3	202 x 140	M16-M32	20 x 2.5 mm <sup>2</sup> , 16 x 4mm <sup>2</sup> , 12 x 6 mm <sup>2</sup> , 12 x 10 mm <sup>2</sup> , 10 x 16 mm <sup>2</sup> , 6 x 35 mm <sup>2</sup> terminals or 14 x 4 mm <sup>2</sup> mini terminals	CCG Bottom entry angle box – 3 entries positioned at the bottom of the box. One entry closest to the rim of the box and two entries to the base of the box
3 way bottom entry box Size 1	128 x 112	M16-M20	8 x 4 mm <sup>2</sup> mini terminals	CCG Bottom entry box – 3 entries positioned at the bottom of the box. One entry closest to the base of the box and two entries to the rim of the box
3 way bottom entry box Size 2	162 x 160	M16-M25	12 x 2.5 mm <sup>2</sup> , 10 x 4mm <sup>2</sup> , 8 x 6 mm <sup>2</sup> , 7 x 10 mm <sup>2</sup> , 6 x 16 mm <sup>2</sup> , 3 x 35 mm <sup>2</sup> terminals or 12 x 4 mm <sup>2</sup> mini terminals	CCG Bottom entry box – 3 entries positioned at the bottom of the box. One entry closest to the base of the box and two entries to the rim of the box
Y box Size 0	102 x 81	M16-M20	6 x 4 mm <sup>2</sup> mini terminals	CCG Posi Fit Y box – 2 entries positioned on the

Issued on: 2021-06-02

Director:



Nanyang Explosion Protected Electrical  
Apparatus Research Institute Co.,Ltd.







# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

## (Annex)

No.: 2021312303000506

Page 3 of 6

				side of the box and 1 entry positioned on the opposite side of the box
Y box Size 1	118 x 111	M16-M20	10 x 2.5 mm <sup>2</sup> , 8 x 4mm <sup>2</sup> , 6 x 6 mm <sup>2</sup> , 5 x 10 mm <sup>2</sup> or 8 x 4 mm <sup>2</sup> mini terminals	CCG Posi Fit Y box – 2 entries positioned on the side of the box and 1 entry positioned on the opposite side of the box
Y box Size 2	138 x 123	M16-M25	12 x 2.5 mm <sup>2</sup> , 10 x 4mm <sup>2</sup> , 8 x 6 mm <sup>2</sup> , 7 x 10 mm <sup>2</sup> , 6 x 16 mm <sup>2</sup> , 3 x 35 mm <sup>2</sup> terminals or 10 x 4 mm <sup>2</sup> mini terminals	CCG Posi Fit Y box – 2 entries positioned on the side of the box and 1 entry positioned on the opposite side of the box
Y box Size 3	200 x 150	M16-M32	20 x 2.5 mm <sup>2</sup> , 16 x 4mm <sup>2</sup> , 12 x 6 mm <sup>2</sup> , 12 x 10 mm <sup>2</sup> , 10 x 16 mm <sup>2</sup> , 6 x 35 mm <sup>2</sup> , 5 x 70 mm <sup>2</sup> terminals or 14 x 4 mm <sup>2</sup> mini terminals	CCG Posi Fit Y box – 2 entries positioned on the side of the box and 1 entry positioned on the opposite side of the box
H box Size 1	118 x 94	M16-M20	10 x 2.5 mm <sup>2</sup> , 8 x 4mm <sup>2</sup> , 6 x 6 mm <sup>2</sup> , 5 x 10 mm <sup>2</sup> , 4 x 16 mm <sup>2</sup> terminals or 8 x 4 mm <sup>2</sup> mini terminals	CCG Posi Fit H box – 2 entries positioned on the side of the box and 2 entries positioned on the opposite side of the box
H box Size 2	138.5 x 100	M16-M25	12 x 2.5 mm <sup>2</sup> , 10 x 4mm <sup>2</sup> , 8 x 6 mm <sup>2</sup> , 7 x 10 mm <sup>2</sup> , 6 x 16 mm <sup>2</sup> , 3 x 35 mm <sup>2</sup> terminals or 10 x 4 mm <sup>2</sup> mini terminals	CCG Posi Fit H box – 2 entries positioned on the side of the box and 2 entries positioned on the opposite side of the box
ST Box Strut box Size 1	100 x 96	M16-M20	4 x 2.5 mm <sup>2</sup> or 6 x 4 mm <sup>2</sup> mini terminals	CCG Posi ST Box strut box – 2 entries positioned on opposite sides with multiple gland entry sizes.
Angle Box	121 x 100	M20-M25	12 x 2.5 mm <sup>2</sup> , 10 x 4mm <sup>2</sup> , 8 x 6 mm <sup>2</sup> , 7 x 10 mm <sup>2</sup> ,	CCG Angle Box – 3 entries positioned at the bottom of

Issued on: 2021-06-02

Director:



Nanyang Explosion Protected Electrical  
Apparatus Research Institute Co.,Ltd.







# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

## (Annex)

No.: 2021312303000506

Page 4 of 6

Size 2			6 x 16 mm <sup>2</sup> , 3 x 35 mm <sup>2</sup> terminals or 10 x 4 mm <sup>2</sup> mini terminals	the box
Multi Box PosiFit Assembly B	(Rectangular) 196 x 132 x 109	See entry amount and arrangement	20 x 2.5mm <sup>2</sup> , 16 x 4mm <sup>2</sup> , 12 x 6mm <sup>2</sup> , 12 x 10mm <sup>2</sup> , 10 x 16 mm <sup>2</sup> , 6 x 35mm <sup>2</sup> , 6 x 50mm <sup>2</sup> , 5 x 70mm <sup>2</sup> terminals or 14 x 4mm <sup>2</sup> mini terminals.	The entries could vary, with the A/C of the gland being the min distance between the entries.
Multi Box PosiFit Assembly C	(Rectangular) 278 x 200 x 117	See entry amount and arrangement	46 x 2.5mm <sup>2</sup> , 32 x 4mm <sup>2</sup> , 28 x 6mm <sup>2</sup> , 23 x 10mm <sup>2</sup> , 14 x 16 mm <sup>2</sup> , 6 x 35mm <sup>2</sup> , 12 x 50mm <sup>2</sup> , 10 x 70mm <sup>2</sup> , 8 x 95/120mm <sup>2</sup> terminals or 35 x 4mm <sup>2</sup> mini terminals.	The entries could vary, with the A/C of the gland being the min distance between the entries.

IP degree: IP66/IP67/IP68(2m/cont)

Ex marking: Ex e IIC T6 Gb,

Ex tD A21 IP66/IP67/IP68 T70°C, Ex tD A22 IP66/IP67/IP68 T70°C

- Producers should organize production in accordance with the technical documents approved by the certification body.

2. Specific conditions of safety use:

- Ambient temperature range: -60°C~+40/55°C.
- For enclosures that do not utilise locking screws on the cover / lid, only the CCG tool supplied shall be used for opening and closing.
- Under certain extreme circumstances, the polycarbonate (clear) cover incorporated in the enclosure may generate an ignition-capable level of electrostatic charge. Therefore, the enclosure shall not be installed in a location where the external conditions are conducive to the build-up of electrostatic charge on such surfaces. In addition, the equipment shall only be cleaned with a damp cloth.

Issued on: 2021-06-02

Director:



Nanyang Explosion Protected Electrical Apparatus Research Institute Co.,Ltd.







# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

## (Annex)

No.: 2021312303000506

Page 5 of 6

- When fitted with the polycarbonate (clear) cover, the enclosure shall be installed to prevent direct UV exposure of internal components.
- Suitably CCC certified cable glands and/or plugs shall be used in the enclosures threaded entries.
- The Junction boxes shall only be used with the following CCC certified terminals. Specific installation conditions as set by the terminal manufacturer / terminal certification, shall be considered. This includes considering the use of the applicable partitions and end plates for the terminal blocks, conductor installation, tightening down of terminal block screws etc.

Manufacturer	Ex coding	Type	Size
Weidmuller	Ex e IIC Gb	AKZ4 and AKE4	4 mm <sup>2</sup>
Weidmuller	Ex e IIC Gb	AKZ 2.5	2.5 mm <sup>2</sup>
Weidmuller	Ex e IIC Gb	WDU & WPE 2.5, 4, 6, 10, 16, 35 and 70N	2.5 mm <sup>2</sup> , 4mm <sup>2</sup> , 6mm <sup>2</sup> , 10 mm <sup>2</sup> , 35mm <sup>2</sup> and 70 mm <sup>2</sup>

- Terminal blocks shall only be utilised on the applicable rail and shall allow sufficient space to make connections and to close the cover / lid.
- The creepage and clearance between terminal blocks and from the terminal block to any earthed / bonded metallic part shall comply with the GB3836.3 requirements for the applicable voltage of the terminal blocks.
- The current per circuit in the junction box is limited by the size of the conductor and shall not exceed the following:

Max. current		Conductor / terminal block size
<55°C ambient	<40°C ambient	
8.34 A	11.90 A	2.5 mm <sup>2</sup>
11.12 A	15.86 A	4 mm <sup>2</sup>
14.25 A	20.33 A	6 mm <sup>2</sup>
19.81 A	28.26 A	10 mm <sup>2</sup>
26.42 A	37.68 A	16 mm <sup>2</sup>
43.46 A	61.98 A	35 mm <sup>2</sup>

Issued on: 2021-06-02

Director:



Nanyang Explosion Protected Electrical Apparatus Research Institute Co.,Ltd.







# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION (Annex)

No.: 2021312303000506

Page 6 of 6

52.50 A	74.88 A	50 mm <sup>2</sup>
66.75 A	95.21 A	70 mm <sup>2</sup>
82.75 A	-	95 mm <sup>2</sup>
94.57 A	-	120 mm <sup>2</sup>

- See instruction for other information.

3. Certificate related report(s):

- Type test report: CQST2102C045

- Factory inspection report: CN2021Q010186

4. Certificate change information: None

Issued on: 2021-06-02

Director:



Nanyang Explosion Protected Electrical  
Apparatus Research Institute Co.,Ltd.

